



Water Quality Chemistry Services Lead School Testing Report Date: 6/7/17

Ingenuity Charter

| Sample ID | Sample Date | Sample Time | Source | External ID | Lead | Units |
|-----------|-------------|-------------|----------|---------------|------|-------|
| W1172142 | 05/26/17 | 06:01 AM | SAMPLE 1 | 3710020-CBC-A | < 5 | ug/L |

Source Description

SAMPLE 1 Classroom Bldg. 100C, Exterior North wall, adjacent to office 100A, dual bubbler fountain, right bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L Action Level (AL) = 15 ug/L

Doug Campbell Senior Chemist